

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No:** 1080-0226:105

Page 1 of 1

**CATEGORY:** Walls/Partitons

**LISTEE:** USG Interiors, 1000 Crocker Road, Westlake OH 44145  
Contact: \*Phil Shaeffer (312) 606-3738 Fax (312) 214-6629

**DESIGN:** Model CRUSADER II system. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name and wall design and rating and CSFM label on wall panels.

**APPROVAL:** Listed as a 1-hour fire-rated non-bearing noncombustible wall assembly.

\*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager